



- NOTES:
1. MINIMUM 25 VA
NOTE: POWER CONSUMPTION REQUIREMENTS WILL VARY DEPENDING UPON FIELD SUPPLIED/MOUNTED ACCESSORIES.
 2. MAXIMUM 10 VA.
 3. SUPPLIED, MOUNTED, WIRED AND/OR PIPED BY MFG.
 4. LOW TUBING IS BLUE, HIGH IS RED
 5. EARTH GROUNDING OF CHASSIS MUST BE PROVIDED BY OTHERS IN THE FIELD. (IF REQUIRED).
 6. REFER TO MOTOR WIRING DIAGRAM FOR TRANSFORMER AND FAN RELAY WIRING (IF APPLICABLE).
 7. 8' CABLE PROVIDED BY JCI FOR WIRING OF FIELD PROVIDED VALVE. CABLE ONLY PROVIDED ON UNITS WITH HOT WATER COILS
 8. CONNECT CONTROLLER TO THERMOSTAT BETWEEN SA BUS. CONNECTION MAY ALSO BE MADE USING RJ45 JACK.
 9. SEE ORDER ACKNOWLEDGEMENT FOR OPTIONAL ITEM REQUIREMENTS.

LEGEND

---	TUBING	AMP PLUG FEMALE PIN	AMP PLUG MALE PIN
---	FACTORY WIRING	WIRE NUT	LEVER NUT
M	MALE QUICK	AMP PLUG	GND RIVET
F	FEMALE QUICK	6 TP	WALL NUT
---	FIELD WIRING		
---	OPTIONAL ITEM		

UNCONTROLLED DOCUMENT WHEN PRINTED

THIS DRAWING MAY NOT REFLECT THE MOST CURRENT REVISION. PLEASE CHECK TO MAKE SURE DRAWING IS CURRENT.

THIS DRAWING CONTAINS PROPRIETARY DATA. UNAUTHORIZED DISCLOSURE REPRODUCTION, OR USE IS STRICTLY PROHIBITED WITHOUT WRITTEN PERMISSION.

TITLE:	WD, FAN CONTROLS, FPC-ZEC102 SUBMITTAL	MATERIAL:	
--------	--	-----------	--

REVISION DESCRIPTION		ZONE	
REVISED FOR ZEC DESIGN CHANGES (PRESSURE SW,SAT & DAT) AS PER SEQUENCE OF OPERATION			
ECR NO.	BY	DATE	CK BY
3889	SP	03/29/19	AR / JAC
DO NOT SCALE DRAWING DIMENSIONS ARE IN INCHES UNLESS OTHERWISE NOTED		SCALE	PART NO.
		NTS	87-10983 -00
		SHEET	DRAWING NO.
			87-10983
		REV	
			01